

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF BARNESBURG WATER)	
ASSOCIATION FOR A DEVIATION FROM THE)	
REQUIREMENTS OF 807 KAR 5:066, SECTION)	CASE NO. 89-241
5(4) REGARDING WATER STORAGE)	

O R D E R

By application received August 28, 1989, Barnesburg Water Association ("Barnesburg Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Barnesburg Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 100,000 gallons,¹ and its current water storage capacity is 100,000 gallons.

The Commission, having reviewed the application and being advised, is of the opinion and finds that Barnesburg Water is in substantial compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4), and therefore its application for a deviation is moot.


¹ Barnesburg Water purchased in 1988 a total of 37,996,000 gallons of water, or approximately 103,814 gallons daily. It sold a total of 37,046,000 gallons of water, or approximately 101,219 gallons daily. Annual Report of Barnesburg Water Association for the year ending December 31, 1988, page 12.

IT IS THEREFORE ORDERED that the application of Barnesburg Water for permission to deviate from the requirements of Commission 807 KAR 5:066, Section 5(4), is dismissed.

Done at Frankfort, Kentucky, this 4th day of October, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director